



ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

REVISED

3-2016

STANDARD


FIRE CHIEF APPROVAL

3-10-2016

EFFECTIVE DATE

307.4.2



RECREATIONAL FIRE OPEN BUILT IN STYLE

In accordance with the California Fire Code Section 307.4.2 Recreational Fires:

Recreational fires shall not be conducted within 25 feet of a structure or combustible material. Conditions which could cause a fire to spread within 25 feet of a structure shall be eliminated prior to ignition.

- ❖ Fires in approved containers that are not less than 15 feet from a structure.
- A charged garden hose shall be present at all times.
- An adult shall be present at all times and fire pit shall be supervised at all times.
- The flame shall not exceed two feet in height above the ground level.
- NO BURNING of household waste matter.

RECREATIONAL OPEN FIRE PITS