

ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

REVISED

08/2019

STANDARD

17A/30

EFFECTIVE DATE

FIRE CHIEF APPROVAL

INSPECTION, TESTING AND MAINTENANCE						
I = INSPECTION P= PASS F= FAIL N/A NOT APPLICABLE						
ITEM		DESCRIPTION	NFPA 17A CA ED. REF.	DATE	COMMENTS ONLY	Pass, Fail, N/A
1.1	-	Manual Actuators are Unobstructed (i.e Remote Pull Station)	7.2.2(2)			
1.2	 	Tamper Indicators & Seals Intact	7.2.2(3)			
1.3	_	Maintenance Tagin Place	7.2.2(4) Title 19 §906			
1.4	ı	No Obvious Physical Damage	7.2.2(5)			
1.5	I	Gauge readings within Proper Limits (stored Pressure Only)	7.2.2(6)			
1.6	ı	Blow-off Caps in Place & undamaged	7.2.2(7)			
1.7	I	Hoods, Ducts, Filters in place and Clean	CFC 607.3.3			
1.8	1	Hood, Ducts & Protected Cooking Appliances Have not been modified or relocated.	7.2.2(8)			











MONTHLY PRE-ENGINEERED FIXED FIRE SUPPRESSION SYSTEM INSPECTION SHEET.