



Alpine Fire Protection District

1364 Tavern Road Alpine, CA 91901
Phone: 619 445-2635 Fax: 619 445-2634

To Responsible Party,

This notice is to advise you that corrective matters at the above listed address were noted at the time of our inspection. It was found that the use of BBQ's under combustible construction is present. This is a violation of the fire code and is not permitted. Immediate action is needed to be taken on this matter. This notice is to advise you and or your board that a written issuance is now created and you are responsible for correcting this matter. Alpine Fire Department is not responsible for notifying each tenant on the property.

I understand that this is a policing issue and will require notices to all tenants. Please remind all tenants that the use of BBQ's LP or charcoal is not allowed under the patios or within 10 feet from combustible materials.

Your cooperation is greatly appreciated and I look forward to working with you and your staff in the near future to resolve any further issues. Please feel free to contact me at my office with any questions or comments.

CFC 2019 Chapter 3 Section 308.1.4

Open Flame cooking devices: Charcoal burners and other open flame cooking devices shall not be operated on combustible balconies or within 10 feet of combustible construction.



These are ok to use.



This is not ok to use within 10' of combustible construction

Jason McBroom
Fire Marshal
Alpine Fire Protection District
1364 Tavern Road
Alpine, Ca. 91901
Office: 1-619-445-2635 x 308
Cell: 1-619-407-0592
jmcbbroom@alpinefire.org

