



ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

REVISED

09/2013

STANDARD

[Signature]
FIRE CHIEF APPROVAL

3-31-2014

EFFECTIVE DATE

13-8.17

By order of the Fire Chief all Fire Department Connections shall have the Knox caps installed with-in the next Title 19 five year.

1. Acquire approved Knox application form from Alpine Fire Protection District office and fill in all fields, mail back to Knox Corporation.
2. Once your new Knox FDC caps have been mailed call the Fire Prevention office to schedule the officer to install caps to the swivel connections.
3. All new construction requiring a FDC shall have caps in place prior to final.
4. All existing FDC shall have been witnessed back flushed by the local fire authority prior to the installation of the new FDC caps.
5. Fire Department Connection signs shall have raised or engraved lettering 1" in height attached to the riser as per Alpine Fire Protection Standard FDC Standards.
6. Fire Department Connections shall have 2 coats of oil base Rustoleum Safety Red K7764 painted to protect metal piping exposed as per NFPA 13 Chapter 8.16.4.2.1



KNOX FIRE DEPARTMENT CONNECTION CAPS INSTALLED