

WHAT	MONTHLY	QUARTERLY	SEMI ANNUALLY	ANNUALLY	TITLE 19 FIVE	SERVICE COMPANY	SERVICE REPAIR COMPANY EMAIL/WEB PAGE	LAST DONE	NEXT DUE	REPORT FORMS
FIRE EXTINGUISHERS	X			X						<a href="#">SERVICE TAG</a>
FIRE ALARM				X						NFPA 72 FORM
FIRE SPRINKLERS		X		X	X					AES 1 AES 2.1 AES 2.2
FIRE HYDRANTS				X						<a href="#">AES 1, 4</a>
EXIT LIGHTS	X			X		YOU ARE REQUIRED TO DO THE MONTHLY PLEASE FIND A CONTRACTOR FOR ANNUAL				<a href="#">LOG BOOK</a>
EMERGENCY LIGHTING	X			X		YOU ARE REQUIRED TO DO THE MONTHLY PLEASE FIND A CONTRACTOR FOR ANNUAL				<a href="#">LOG BOOK</a>
FIXED SUPPRESSION SYSTEM			X							<a href="#">NFPA 17A FORM</a>
HOOD & DUCT			X							SERVICE TAG
FIRE DOORS				X						TAG

NFPA 10 STANDARD FOR PORTABLE FIRE EXINGUISHERS 2013 ED.

NFPA 72 STANDARD NATIONAL FIRE ALARM AND SIGNALING CODE 2016 ED.

NFPA 25 2013 EDITION ONLY APPLIES TO CALIFORNIA. THIS STANDARD IS HOW TO TEST AND MAINTAIN WATER BASED FIRE PROTECTION SYSTEMS

FIRE HYDRANTS SHALL BE MAINTAINED BY PADRE DAM WATER AUTHORITY NO MAINTENANCE DONE BY YOUR STAFF.

EXIT LIGHTS AND EMERGENCY LIGHTING SHALL BE MAINTAINED IN ACCORDANCE TO THE CFC 2016 ED

NFPA 17A & 96 FOR THE SERVICE OF FIXED FIRE SUPPRESSION SYSTEM IN YOUR KITCHEN.

[AES 1](#)

[AES 2.1](#)

[AES 2.2](#)

[AES 10](#)