



ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

REVISED

09-2013

STANDARD

OS&Y

[Signature]
FIRE CHIEF APPROVAL

3-31-2014
EFFECTIVE DATE

1. REFER TO PADRE WATER STANDARDS DRAWING FOR ACTUAL INSTALLATION REQUIREMENTS NOT SHOWN IN THIS DETAIL FOR THE UNDERGROUND SERVICE BEING PROVIDED.
2. LOCATION, TYPE AND INSTALLATION OF DOUBLE DETECTOR CHECK ASSEMBLY SHALL BE APPROVED BY THE ALPINE FIRE PROTECTION DISTRICT.
3. ALL UNDERGROUND FITTINGS AND PIPE SHALL BE INSTALLED IN ACCORDANCE TO THE NFPA 24 STANDARDS.
4. ALL AUTOMATIC FIRE SPRINKLER SYSTEM CONTROL VALVES SHALL BE LISTED AND APPROVED FOR USE INTENDED.
5. ALL EXTERIOR PIPING AND VALVES SHALL BE PAINTED WITH 2 COATS OF RUSTOLEUM OIL BASE SAFETY RED K7764 AS PER THE NFPA 13 CHAPTER 8.16.4.2
6. ALL CONTROL VALVES SHALL BE INSTALLED WITH AN APPROVED LOCK WITH MEANS OF BREAKAWAY.
7. ALL CONTROL VALVES SHALL BE INSTALLED WITH APPROVED SIGNS AS PER ALPINE FIRE PROTECTION SIGN STANDARD.
8. ALL CONDUIT AND FITTINGS INSTALLED TO THE TAMPER EQUIPMENT SHALL BE STRAPPED OR RESTRAINED NOT BE A TRIPPING HAZARD AND SECURED IN ACCORDANCE TO NATIONAL ELECTRICAL CODE.
9. MINIMUM OF 36" CLEARANCE IS REQUIRED AROUND ALL SIDES OF CONTROL VALVES AT ALL TIMES.



OSY WITH FDC INSTALLATION REQUIREMENTS