



ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

[Signature]

 FIRE CHIEF APPROVAL

3-31-2014

 EFFECTIVE DATE

REVISED
1-2014
 STANDARD
 F-Title 19

Alpine Fire Protection District has adopted the following policy for the witness testing of all Title 19 five year services for all wet automatic based fire systems in the Alpine District.

Procedures for Title 19 Five year Services:

- Contact the AFPD 48 hours in advance to schedule the witness inspection. If testing is performed without having a witness of AFPD Fire Prevention office the test will not be recognized and retest shall be completed.
- C 16 contractor shall have the fire system prepared for the arrival of AFPD inspector to witness the back flush of FDC and the internal inspection of any alarm valves.
- AFPD inspector shall sign off that the witness of said test has been completed on the front page of the Automatic Extinguishing System Inspection report form AES 1 approved by the State Fire Marshal office.
- A "dirty report" shall be presented to the AFPD within 7 days after the test for AFPD review and comments. This report shall provide description of all correctable items noted at time of service. AFPD reserves the right to waive or require additional requirements as per Health & Safety Code 13195.
- AFPD inspector shall sign off on the repairs noted before any work shall take place between the owner of said business and contractor.
- All repairs shall be completed within a timely manner. The intent is not to have correctable items be in violation for more than (30) days from the date of Title 19 five year service. Systems that are out of service or fire life safety hazards immanent to the threat of life or the threat to property shall be repaired immediately. Fire watch precautions shall be in place, if system shall not be restored immediately.
- Once all repairs from the approved repairs list have been completed and customer is completely satisfied with repairs the Title 19 five year service label, will then be adhered to the system.
- After Title 19 five year service label is placed on the system certifying compliance the local fire authority shall receive the "clean report" within 7 days of the placement of certification label.

DO NOT REMOVE BY ORDER OF THE STATE FIRE MARSHAL												
 LICENSE# <input type="checkbox"/> 5 YEAR <input type="checkbox"/> 3 YEAR <input type="checkbox"/> ANNUAL <input type="checkbox"/> NEW	OWNER IS RESPONSIBLE FOR MAINTAINING RECORDS						SPRINKLER					
	X _____ SIGNATURE COMPANY NAME ADDRESS PHONE NUMBER X _____ PRINT NAME						STANDPIPE					
							FIRE PUMP					
							WATER TANK					
							FOAM					
							WATER SPRAY					
							WATER MIST					
							PRIVATE FIRE SERVICE MAIN					
	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	

Title 19 Five Service of Automatic Water Based Fire Extinguishing Systems