



# ALPINE FIRE PROTECTION DISTRICT

## FIRE PREVENTION POLICY MANUAL

REVISED

01/14

*[Signature]*  
FIRE CHIEF APPROVAL


3-31-2014

EFFECTIVE DATE

STANDARD

503.2.4

### MINIMUM REQUIREMENTS



COMMERCIAL & RESIDENTIAL  
Serving more than 2 structures

- This diagram is the “*minimum*” requirement.
- For parking on 1 side of roadway, Add 8’
- For parking on 2 sides of roadway, Add 16’
- For parking all around cul-de-sac add 8’ all the way around
- Parking shall be parallel only - No head in parking allowed

## CUL-DE-SAC REQUIREMENTS