

ALPINE FIRE PROTECTION DISTRICT

FIRE PREVENTION POLICY MANUAL

3-31-2014

EFFECTIVE DATE

REVISED

01/14

STANDARD

SOG

SIGNS AND PLACARDS

New and existing buildings shall have signs to identify items if importance to firefighters.

FIRE CHIEF APPROVAL

The Alpine Fire Protection District shall define the designations to be placed within the sign. Fire departments shall conduct annual inspections to verify compliance with signage and the owner of a building shall be responsible for the maintenance and updates to the signs.


Basic signage consists of but not limited to:

Doors to all electrical rooms, alarm control panel rooms, fire protection and utility equipment rooms, storage of any hazardous material or fire equipment shall be labeled or placarded.

Different signs shall be in accordance with the latest California Fire Code regulations and placed as recommended.

FIRE SPRINKLER RISER ROOM

CONTRASTING BACK GROUND: RED OR BLACK LETTERS ON WHITE VINYL, ALUMINUM OR RIGID PLASTIC



SIGNS AND PLACARDS