



Alpine Fire Protection District

1364 TAVERN RD. ALPINE, CA 91901-3831
 BUSINESS (619)445-2635 • FAX (619)445-2634

Monthly Inspection and Record of R-3.1 Occupancy.

In accordance with the California Fire Code 2019 edition Chapter 9 Section 907.2.10.2.3

907.2.10.2.3 Group R-3.1 In all facilities housing a bedridden client, smoke alarm shall receive their primary power from the building wiring when such wiring is served from a commercial source and shall be equipped with a battery back-up. Smoke alarms shall be electronically interconnected so as to cause all smoke alarms to sound a distinctive alarm signal upon actuation of any single smoke alarm. Such alarm signal shall be audible throughout the facility at a minimum level of 15 db above ambient noise level. These devices need not be interconnected to any other fire alarm device, have a control panel, or be electronically supervised or provided with emergency power.

The required monthly service of the manual alarm device shall be completed and recorded below for reference. This is to ensure operation of the devices and safety equipment. Your semi-annual evacuation drills may be at your choosing.

Should any correction be noted please make contact with a service repair company immediately to ensure that no lapse of service is present. If you have any questions or would like further detailed instructions please feel free to contact the Fire Marshal. 619-445-2635 x 308

Month	Location Tested	Audible Alarms	Visual Alarms	System Reset	Date Tested	Time Tested	Restore Complete	Corrections
January								
February								
March								
April								
May								
June								
July								
August								
September								
October								
November								
December								

Contact your fire alarm vendor to place system in test mode prior to any testing. Please also notify local fire department prior when testing is to be completed. Any issues alarms not resettable please contact your fire alarm vendor immediately do not disconnect any devices.