

SEMI-ANNUAL BATTERY REPLACEMENT RECORD LOG BOOK

To be current and up to date on the replacement of the batteries in your existing battery operated smoke detector units they must have preventive maintenance. The replacement of all batteries ensures the proper operation of each unit. Rule of thumb is always to replace at time change. This log book will keep a reminder of when that is and record that replacements have been made.

Citing from: 2019 California Fire Code Chapter 9 Section 907.8.5 Inspection, Testing and Maintenance.

The building owner shall be responsible to maintain the fire and life safety systems in an operable condition at all times. Service personnel shall meet the qualification requirements of NFPA 72 for maintaining, inspecting and testing such systems. A written record shall be maintained and shall be made available to the fire code official.

In the NFPA 72- National Fire Alarm and Signaling Code

Chapter 14 Section 14.4.5.6 Replacement of smoke alarms in one and two family dwellings. Unless otherwise recommended by the manufactures published instructions, single and multi station smoke alarms installed in one and two family dwellings shall be replaced when they fail to respond to operability tests but shall not remain in service longer than 10 years from the date of manufacture. 14.4.5.9- When batteries are used as a source of energy, they shall be replaced in accordance with the alarm equipment manufacture's published instructions.

Number	Location	Battery	Date in	10 Year	Battery	Battery	Replace	Sticker
		Operated	Service	Replace	In	Change	Date	Placed
1	classroom 1	yes	2004	2014	Mar-13	Nov-13		Y/N
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								